

VENTILATION CALCULATION FOR THE TRANSFORMER ROOM

1 ASSUMPTION

- Ambient Temperature	=	115 F
- Max. Allowed Temp. Rise	=	10.8 F
- Sub- Station Ref. No.		1
- Number Of Transformers	=	1 Nos.
- Transformer Rateing	=	1600 KVA
- Number Of Transformers	=	1 Nos.
- Transformer Rateing	=	1250 KVA
- Power Factor	=	0.8
- Transformer Eff.	=	0.98

2 CALCULATION

Heat Loss / Transformer

$$\begin{aligned}
 &= (1 \times 1600 + 1 \times 1250) \times 0.8 \times (1 - 0.98) \\
 &= 45.6 \text{ KW} \\
 &= 45600 \text{ Watt}
 \end{aligned}$$


Total Heat Dissipation

$$\begin{aligned}
 &= 45600 \times 3.413 \\
 &= 155632.8 \text{ Btu/hr} \\
 &= 1.08 \times \text{CFM} \times \text{Temp. Rise} \\
 &= 1.08 \times \text{CFM} \times 10.8
 \end{aligned}$$

Air Quantity Required for ventilation

Then :-

$$\text{The Air Quantity} = 13,343 \text{ CFM}$$



3 VENTILATION SYSTEM DISCRPTION

Number of fans	=	2	
Fan Capacity / Each	=	6,672	= CFM
Fan rating KW/Each	=	1.37	KW
Fan st. Pressure	=	1	IN.WG

VEVTILATION CALCULATION FOR THE TRANSFORMER ROOM

1- **ASSUMPTION**

- Ambient Temperature = 115 F
- Max. Allowed Temp. Rise = 10.8 F
- **Sub- Station Ref. No.** = 2
- Number Of Transformers = 0 Nos.
- Transformer Rateing = 0 KVA
- Number Of Transformers = 3 Nos.
- Transformer Rateing = 1250 KVA
- Power Factor = 0.8
- Transformer Eff. = 0.98

2- **CALCULATION**

Heat Loss / Transformer

$$\begin{aligned} &= (0 \times 0 + 3 \times 1250) \times 0.8 \times (1 - 0.98) \\ &= 60 \text{ KW} \\ &= 60000 \text{ Watt} \end{aligned}$$

Total Heat Dissipation

$$\begin{aligned} &= \\ &= 60000 \times 3.413 \\ &= 204780 \text{ Btu/hr} \\ &= 1.08 \times \text{CFM} \times \text{Temp. Rise} \\ &= 1.08 \times \text{CFM} \times 10.8 \end{aligned}$$

Air Quantity Required for ventilation

Then :-

$$\text{The Air Quantity} = 17,557 \text{ CFM}$$

VENTILATION SYSTEM DISCRPTION

- Number of fans = 2
- Fan Capacity / Each = 8,778 = CFM
- Fan rating KW/Each = 1.07 KW
- Fan st. Pressure = 0.5 IN.WG

VEVILATION CALCULATION FOR THE TRANSFORMER ROOM

PROJECT :

1- **ASSUMPTION**

- Ambient Temperature	=	115 F
- Max. Allowed Temp. Rise	=	10.8 F
- <u>Sub- Station Ref. No.</u>	=	1
- Number Of Transformers	=	1 Nos.
- Transformer Rateing	=	1000 KVA
- Number Of Transformers	=	0 Nos.
- Transformer Rateing	=	1000 KVA
- Power Factor	=	0.8
- Transformer Eff.	=	0.98

2- **CALCULATION**

Heat Loss / Transformer

$$\begin{aligned} &= (1 \times 1000 + 0 \times 1000) \times 0.8 \times (1 - 0.98) \\ &= 16 \text{ KW} \\ &= 16000 \text{ Watt} \end{aligned}$$

Total Heat Dissipation

$$\begin{aligned} &= \\ &= 16000 \times 3.413 \\ &= 54608 \text{ Btu/hr} \\ &= 1.08 \times \text{CFM} \times \text{Temp. Rise} \\ &= 1.08 \times \text{CFM} \times 10.8 \end{aligned}$$

Air Quantity Required for ventilation

Then :-

$$\text{The Air Quantity} = 4,682 \text{ CFM}$$

VENTILATION SYSTEM DISCRPTION

Number of fans	=	1	
Fan Capacity / Each	=	4,682	= CFM
Fan rating KW/Each	=	1.11	KW
Fan st. Pressure	=	1	IN.WG

VENTILATION CALCULATION FOR THE TRANSFORMER ROOM

1- **ASSUMPTION**

- Ambient Temperature = 115 F
- Max. Allowed Temp. Rise = 10.8 F
- **Sub- Station Ref. No.** = 4
- Number Of Transformers = 6 Nos.
- Transformer Rateing = 1600 KVA
- Number Of Transformers = 4 Nos.
- Transformer Rateing = 0 KVA
- Power Factor = 0.8
- Transformer Eff. = 0.98

2- **CALCULATION**

Heat Loss / Transformer

$$\begin{aligned} &= (6 \times 1600 + 4 \times 0) \times 0.8 \times (1 - 0.98) \\ &= 154 \text{ KW} \\ &= 153600 \text{ Watt} \end{aligned}$$

Total Heat Dissipation

$$\begin{aligned} &= \\ &= 153600 \times 3.413 \\ &= 524236.8 \text{ Btu/hr} \\ &= 1.08 \times \text{CFM} \times \text{Temp. Rise} \\ &= 1.08 \times \text{CFM} \times 10.8 \end{aligned}$$

Air Quantity Required for ventilation

Then :-

$$\text{The Air Quantity} = 44,945 \text{ CFM}$$

VENTILATION SYSTEM DISCRPTION

- Number of fans = 3
- Fan Capacity / Each = 14,982 = CFM
- Fan rating KW/Each = 2.45 KW
- Fan st. Pressure = 1 IN.WG

VEVTILATION CALCULATION FOR THE TRANSFORMER ROOM

1- **ASSUMPTION**

- Ambient Temperature = 115 F
- Max. Allowed Temp. Rise = 10.8 F
- **Sub- Station Ref. No.** = 5
- Number Of Transformers = 2 Nos.
- Transformer Rateing = 1600 KVA
- Number Of Transformers = 0 Nos.
- Transformer Rateing = 0 KVA
- Power Factor = 0.8
- Transformer Eff. = 0.98

2- **CALCULATION**

Heat Loss / Transformer

$$\begin{aligned} &= (2 \times 1600 + 0 \times 0) \times 0.8 \times (1 - 0.98) \\ &= 51.2 \text{ KW} \\ &= 51200 \text{ Watt} \end{aligned}$$

Total Heat Dissipation

$$\begin{aligned} &= \\ &= 51200 \times 3.413 \\ &= 174745.6 \text{ Btu/hr} \\ &= 1.08 \times \text{CFM} \times \text{Temp. Rise} \\ &= 1.08 \times \text{CFM} \times 10.8 \end{aligned}$$

Air Quantity Required for ventilation

Then :-

$$\text{The Air Quantity} = 14,982 \text{ CFM}$$

VENTILATION SYSTEM DISCRPTION

- Number of fans = 2
- Fan Capacity / Each = 7,491 = 6000 CFM
- Fan rating KW/Each = 0.99 KW
- Fan st. Pressure = 0.5 IN.WG

VEVTILATION CALCULATION FOR THE TRANSFORMER ROOM

1- **ASSUMPTION**

- Ambient Temperature = 115 F
- Max. Allowed Temp. Rise = 10.8 F
- Sub- Station Ref. No. = 6
- Number Of Transformers** = 2 Nos.
- Transformer Rateing = 1250 KVA
- Number Of Transformers = 0 Nos.
- Transformer Rateing = 0 KVA
- Power Factor = 0.8
- Transformer Eff. = 0.98

2- **CALCULATION**

Heat Loss / Transformer

$$\begin{aligned} &= (2 \times 1250 + 0 \times 0) \times 0.8 \times (1 - 0.98) \\ &= 40 \text{ KW} \\ &= 40000 \text{ Watt} \end{aligned}$$

Total Heat Dissipation

$$\begin{aligned} &= \\ &= 40000 \times 3.413 \\ &= 136520 \text{ Btu/hr} \\ &= 1.08 \times \text{CFM} \times \text{Temp. Rise} \\ &= 1.08 \times \text{CFM} \times 10.8 \end{aligned}$$

Air Quantity Required for ventilation

Then :-

$$\text{The Air Quantity} = 11,704 \text{ CFM}$$

VENTILATION SYSTEM DISCRPTION

- Number of fans = 2
- Fan Capacity / Each = 5,852 = 6000 CFM
- Fan rating KW/Each = 0.88 KW
- Fan st. Pressure = 0.5 IN.WG

$\text{FAN (HP)} = \text{St. Pr. (INCH)} \times \text{Flow (CFM)} / (0.9 \times 6356)$
--

